

# CITY OF CLEARLAKE

14050 Olympic Drive  
Clearlake, Ca 95422

**BID OPENS**  
**February 21, 2019 @ 2:30 pm**

## **BID ADDENDUM #1**

**City of Clearlake- Pavement Rehabilitation Project**  
**Highlands Harbor Drive, Harbor Lane, Lakeland Drive, Marine Court & Anchor**  
**Drive**  
**(CONTRACT NO. LF2019(1))**

### **TO ALL BID DOCUMENT HOLDERS:**

The following are clarifications and answers along with some additional information to current bidders.

1. Special Provisions- Section 12-8 "Paving Fabric" 9<sup>th</sup> line of Section 12-8.02 is changed to read, "Public traffic shall not be allowed to drive on the fabric"
2. Special Provisions- Section 12-8 "Paving Fabric" 7<sup>th</sup> line of Section 12-8.02, first sentence is changed to read, "Fabric shall be overlapped to 6" at all joints."
3. Note 3 on sheet C3 of 10 is deleted, "Contractor is cautioned to minimize heavy traffic and equipment traffic along Harbor Lane due to underlying soil instability"
4. A geotechnical report has not been completed for this project.

Please sign this addendum in the place provided and include with your bid. Bids submitted without a signed copy of this addendum may be considered non-responsive and may be rejected.

The undersigned as received and read this addendum.

\_\_\_\_\_

Contractor

\_\_\_\_\_

Name (printed)

\_\_\_\_\_

Signature

\_\_\_\_\_

Date

For Questions, please contact:

Ms. Marisa Hewitt, Assistant Engineer  
Telephone (530) 751-0952  
[mhewitt@cecusa.net](mailto:mhewitt@cecusa.net)